



300TT PROTECTION FLEECE
TO BE USED WHERE NO
INSULATION USED AS PROTECTION

JUTA GP²® HIGH PERFORMANCE DPM
APPLIED ONTO MIN. 40mm SAND BLINDING

**NB - ALL DPCs & MEMBRANES INTERRUPTING
MASONRY BED JOINTS ARE REQUIRED TO BE
BEDDED ABOVE AND BELOW WITH MORTAR**

GP® RADON SUMP CAP LINK
CONNECTED TO SUITABLE
VENTILATION BOLLARD

STANDARD CAVITY TRAY
SEALED TO GAS MEMBRANE
USING JUTA GP® TAPE.

JUTA WP SAM
APPLIED EXTERNALLY TO WALL. PREPARED
WITH 1 COATS OF JUTA GP PRIMER.

**JUTA GP® RADON
SUMP CAP LINK**

JUTA GP® RADON DPC

JUTA GP® RADON SUMP
SUBJECT TO SITE SPECIFIC DESIGN.
CONTACT JUTA FOR FURTHER INFORMATION

STANDARD 110mm PVC-U PIPE

CLIENT	JUTA UK LTD
PROJECT	GP ² Standard Details



- NOTES**
- Detail is generic to application so should be used as a guide not a specific installation detail.
 - GP² is a proprietary radon resistant DPM, manufactured and certified to adhere to the requirements of BRE 211: 2015 as a radon barrier.
 - GP² provides radon protection, in accordance with Approved Doc C (UK) and Technical Guidance Document C (Ireland).
 - Jointing and sealing using tapes is acceptable where anticipated design service life does not exceed 25 years.
 - Jointing and sealing by hot air welding is recommended where the anticipated design service life is required to exceed 60 years.
 - The use of butyl and bitumen based tapes in environments where VOC and Hydrocarbons are a perceived risk should be avoided. A thermal/welded joint system should be adopted.
 - It should be noted that the suitability of the welded joint is defined by the joint integrity, as tested in accordance with CIRIA C735: 2014. This is most commonly tested by air lance integrity testing to ASTM D4437-08: 2013. If the joint passes this test it is deemed acceptable in the verification process.
 - In all cases it is recommended the installation of gas barrier geomembranes is completed by a suitably qualified and accredited installer (NVQ L2/TWI/CSWIP or equivalent). Juta UK can offer advice as to the suitable/recommended installers.
 - All design decisions made by others that might have an impact on the gas and waterproof design performance should be brought to the attention of the design team and Juta UK Ltd. Final decisions and/or any recommendations should be approved by the design team and Juta UK Ltd.
 - Dimensions are not to be scaled from this drawing. All written measurements are to be checked on site by the contractor.
 - All rights described in chapter IV of the copyright, design and patents act 1988 have been generally asserted.

DRAWING TITLE			
JUTA GP² DPM SUSPENDED SLAB, PERIMETER DETAIL: RADON SUMP WITH MEMBRANE BELOW SLAB			
DRAWING NUMBER			
JUTA.GP2.002			
DRAWN BY	CHECKED BY	SCALE	DATE
PD	PF	Not to Scale	Mar. 2020
		MELTON GROVE WORKS BLACKPOOL ROAD LYTHAM FY8 5PL	
		Tel: 01772 754177	